

June 6, 2003

Fort Bragg Dana Grey School
Fort Bragg Unified School District
1197 Chestnut Street
Fort Bragg, California
Case No. 1TMC124

Notice of Proposed No Further Action related to petroleum hydrocarbon discharge.
Comment period ends July 7, 2003.

Problem Description: Fort Bragg Dana Grey School is located in Mendocino County at 1197 Chestnut Street in Fort Bragg. In 1990, Fort Bragg Dana Grey School excavated and removed one 8,000-gallon heating oil underground storage tank (UST). The Mendocino County Tank Abandonment Inspection Report (Inspection Report) indicates that the inspector observed no holes in the tank and that no signs of soil or water contamination were obvious. One water and two soil samples were collected from the excavation pit and analyzed for total petroleum hydrocarbons as diesel (TPH-d), benzene, toluene, ethylbenzene, and total xylenes (BTEX). Laboratory analysis of the excavation pit water sample indicated levels of TPH-d at 490 parts per billion (ppb)

Interim Actions Completed: On June 25, 1991 three monitoring wells MW-1, MW-2, and MW-3 were installed to total depths of 20 feet, 17 feet, and 25 feet respectively below ground surface (bgs). A total of four soil samples and three groundwater samples were collected from the three monitoring wells. All soil and groundwater samples were analyzed for total petroleum hydrocarbons as diesel (TPH-d), benzene, toluene, ethylbenzene, and xylenes (BTEX). All soil and groundwater sample analysis were below laboratory detection limits. Laboratory analysis of groundwater samples collected in January 1994 were below laboratory detection limits.

MtBE Status: MtBE analysis was not required.

Proposed Action: No further action related to the petroleum discharges from the underground tank is proposed.

Case closure with no further action will be completed without further notice unless significant public comment is received prior to July 7, 2003. Please contact Daniel Warner at (707) 576-2671 or warnd@rb1.swrcb.ca.gov with any questions or comments.